

DURASOUND TECHNICAL DETAILS

MANUAL OPERATION OVER 3.4m TALL

HEAD & SILL DETAILS

P2.....Standard

WALL JAMB DETAILS

P3 Standard

FLOATING WALL JAMB DETAILS

P4 Single Parting

P5 Bi-Parting

ELEVATIONS

P6 Single Parting

P7 Bi-Parting

P8 Single Parting Pocket

P9 Bi-Parting Pocket



1. 10mm threaded rod with nuts and washers by main contractor.
Spacing: 600mm centres through opening, 300mm in stack depth areas.

NOTE: All fixings must be kept clear of “Track Fixing Area”

2. Two (2) Layers 17mm x 460mm continuous plywood, screwed and glued, to be parallel with floor. Maximum level tolerance of +/- 5mm. By main contractor.

3. Sound proofing: Insulate above header as required for sound proofing “by others”.

4. Plywood head recessed anywhere between 34 - 75mm above the ceiling.

NOTE: 34mm recess will set MPNZ tracks at ceiling height.















